

From

The Head
Department of Microbiology
PAU, Ludhiana

To

The District Epidemiologist
Office of Civil Surgeon
Ludhiana

Memo No. 1654

Dated: 20/05/22

Subject:

Bacteriological quality of drinking water (IS-10500:1991, BIS New Delhi).

Reference is made to your letter No. M.TECH/LDH/2022/91 dated 16.05.2022 regarding safe water for bacteriological analysis.

REPORT

| S. No. | Address | Source | Coliform organisms | | Faecal Coliform Detect Not detecte |
|--------|--|-------------|--------------------|--|---------------------------------------|
| | | | Present/ Absent | Most Probable Number index (<10/100ml) | |
| 276 | Garden Valley International School, dyalpura, ludhiana | Submersible | Absent | -- | Not Detecte |
| 277 | Sutlej Public sen see school, hawar, ludhiana | Submersible | Absent | -- | Not Detecte |
| 278 | Garden Valley International school, VPO Bhattian, Kohara | Submersible | Absent | -- | Not Detecte |
| 279 | S. Sobha Singh Public School, Raikot | Submersible | Absent | -- | Not Detecte |

INFERENCE

Bacteriologically safe :- 276, 277, 278, 279

Bacteriologically not safe :- nil

Amal
Technician
Water Testing Lab
Department of Microbiology
PAU, Ludhiana

[Signature]
Incharge
Water Testing Lab
Department of Microbiology
PAU, Ludhiana

NOTE: This result relates to the sample provided to us and laboratory is not responsible for drawing/collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the University.

[Signature]
Head
Department of Microbiology

No M-Tech/Lon/22/109

Date 30/5/22

ਪੰਜਾਬ S. Sobha Singh Public School Raikot Ludhiana ਚ
ਸਿੱਖਿਆ ਅਤੇ ਸਿਹਤ ਵਿਭਾਗ ਨੂੰ ਪਤਾ 16/5/22 ਪ੍ਰਿੰਸਿਪਲ ਬਿਮੀ ਨੀ ਨੇ ਭੇਜੇ ਹੋਏ

S.No- 279 ਵਾਲੀ ਸਿੱਖਿਆ ਅਤੇ ਸਿਹਤ ਵਿਭਾਗ ਨੂੰ, Health and sanitation
are being maintained to desired levels. The water is satisfactory
for drinking.

— G. Singh
Distt. Epidemiologist (IDSP)
Civil Surgeon Office,
Ludhiana.